

Checklist of E/OHS Activities for Underground and Aboveground Storage Tanks

Program Contact Person: Roger Graff

Is the Underground and Aboveground Storage Tanks Plan in place? **Yes** No

Is the Plan current? **Yes** No

Has the Plan been reviewed this school year? **Yes** No

Have forms for inventory tracking been provided? **Yes** No N/A

Do existing records accurately reflect purchase use correlation? **Yes** No N/A

Are all USTs registered with the Minnesota Pollution Control Agency? **Yes** No N/A

Are removals or additions of tanks anticipated in this facility? Yes **No** N/A

Notes:



Underground Storage Tank Status

Tank No.	Location	Size	Contents	Registered	Install date
1	High School South of Building	10,000 gal	#2 Fuel Oil	Yes	
2	High School South of Building	10,000 gal	#2 Fuel Oil	Yes	
3	Elementary	10,000 gal	#2 Fuel Oil	Yes	

Regulated Tanks: Motor fuel tanks larger than 110 gallons

Non-regulate Tanks: Heating oil tanks

Requirements for All USTs: Tank must be registered with MPCA

Requirements for Regulated Tanks: Annual tightness testing and inventory control tank must be updated, replaced, or removed by December 22, 1998
Upgrades:

- Overfill protection
- Corrosion protection STPlapproved
- Leak detection

Tightness Testing Results on File:

Dates of past testing: N/A

Records on file:N/A

