

Checklist of E/OHS Activities for Compressed Gas Safety

Program Contact Person(s): Kristine Sellner/Eddy Jaskowiak

Primary Contact: Eddy Jaskowiak

Industrial Arts: N/A

Is the Compressed Gas Plan in place? *Yes No N/A*

Is the Plan current? *Yes No*

Has the Plan been reviewed this school year? *Yes No*

Has the facility been surveyed for compressed gas inventories? *Yes No*

Has training been conducted for affected personnel? *Yes No*

Training conducted on?

Are records established/maintained for gas inventory? *Yes No*

01/06/2019 SC

No welding program offered at this time. -sc 07-16-2020

Compressed Gas not being used at this time -01-06-2020



COMPRESSED GAS FIELD REVIEW

Compressed Gas Inventory

<i>Date: 2/2/2018</i>	<i>Program Contact Person: Shawn Hiebertsn</i>
<i>Department: Technology</i>	<i>Department Responsible Person: Shawn Hiebertsn</i>
<i>Location: Metal Shop Area</i>	
<i>Cylinders:</i> ☐ O2 <u>3</u> ☐ Acetylene <u>2</u> ☐ NH3 _____	☐ CO2 _____ ☐ Argon _____ ☐ Argon/CO2 <u>1</u> ☐ Other _____

Compliance Check List

	Yes/ No	
1. Are cylinders in well-ventilated area?	X	
2. Are cylinders stored separate from flammable by at least 20 feet?	X	
3. During storage are oxygen cylinders separated from fuel gas cylinders, unless on welding cart?	X	
4. Are cylinders kept away from sources of heat (below 130 F)?	X	
5. Are safety chains used at all times on both full and empty cylinders? (2/3rds from top of cylinder)	X	
6. Are empty cylinders maintained separate from full cylinders?	X	
7. Are cylinders kept away from sources of ignition such as electricity, excessive heat or oily rags?	X	
8. Are carts designed specifically for gas cylinders available?	X	
9. Are damaged cylinders, valves/hoses removed from service?	X	
10. Are all cylinders properly labeled with the contents?	X	

