

Checklist of E/OHS Activities for Community Right-to-Know

Program Contact Person: Jim Slettedahl

Is the Community Right-to-Know Plan in place? **Yes** No N/A

Is the Plan current? **Yes** No N/A

Has the Plan been reviewed this school year? **Yes** No N/A

Are quantities of stored and used designated hazardous materials documented and verified? **Yes** No N/A

Note: (2) Tanks are located in custodial office. They are less than the required quantity to be reported.

Where are the documents stored? Activity Manual

Have the State Emergency Response Commission and local fire department been notified of hazardous materials on school grounds? Yes No **N/A**

When were they notified? N/A
(date)

Has training been provided? Yes No **N/A**

Date: N/A

Presenter: N/A

No changes have been noted for school year 2018-19-SC



Inventory Form

Client: ECHO Charter School

Contact Person: Jim Sletterdahl			Date: 2/19/2019			
Hazardous Material	Quantity	Location	Reported on Tier Two	Installation Date(s)		
# 2 Fuel oil	260 gal X 2 520 total gallons	Custodial room next to boiler room	N/A			

Note: The minimum quantity of reportable chemicals is 10,000 lbs. The above fuel remains less than required for reporting. SC 2/19/2019

