

# IAQ Monitoring

Client: Echo Charter School

Measuring Device: TSI AQ-Calc, Model 7545		Calibration: Pre _____ Post _____	
Reason for Testing: Annual IAQ Walk Through			
Building: Adrian High School			
Location	Parameter	Results	Recommendations
Hall 1 (District Office)	CD	45	
	CO	0	
	Humidy	60.8	
Hall 2	CD	131	
	CO	0	
	Humidy	63.8	
gym	CD	5	
	CO	0	
	Humidy	60.9	
kitchen	CD		
	CO		
	Humidy		
Class Room	CD		
	CO		
	Humidy		
Class Room	CD		
	CO		
	Humidy		

**Summary Observations:** The building appeared to be well within the range of acceptable indoor quality when using CO2 as a standard of acceptability. When measured in term of relative humidity values were consistently in the lower range of acceptability.

Completed by: Shane Carlson Date 4-12-2018

